



**TOWN OF WESTWOOD
COMMONWEALTH OF MASSACHUSETTS**

INVITATION FOR BIDS

**Wentworth Hall Building Relocation Project
Bid # ECON-20-B-005
Addendum 01
November 7 2019**

I. GENERAL INFORMATION FOR ADDENDUM 01

- Addendum 01 extends the Bid due time. All Bids must be delivered by **12:30 pm on Thursday, November 21, 2019**.
- Addendum 01 requests that all potential bidders send their contact information to procurement@townhall.westwood.ma.us. Doing so will put the firm on a list to be notified of any changes to the IFB.
- Addendum 01 revises Attachment A, Scope of Work, in the following manner:
 - The scope of demolition is to be revised. Drawings and scope currently call for the siding and windows of the existing building to be relocated and be removed prior to moving of the building. Delete that scope. Existing siding and existing windows of the structure to be moved are to remain on the building.
 - The following are approximate quantities of hazardous materials are to be removed in accordance to the report prepared by Envirotest Laboratories, Dated 8/14/2019:
 - Friable pipe wrap Type TSI, located in the Basement: 15 feet
 - Non-friable floor tile Type MM, located on the First Floor: 120 square feet
 - Non-friable floor mastic Type MM, located on the First Floor: 120 square feet
 - Attached are Drawings S-1.0, S-1.1 and S-1.2A. This set indicates the support system needed to support the existing building during the move and when at its final location. The moving contractor has the option to propose alternative methods to support the building both during the move and its final location. File name is "ECON-20-B-005 Addend 01 Atch A Supplement."



**TOWN OF WESTWOOD
COMMONWEALTH OF MASSACHUSETTS**

II. ADDENDUM 01 RECEIPT ACKNOWLEDGEMENT FORM

BIDDERS MUST ACKNOWLEDGE RECEIPT OF ADDENDUM WITH THE BID SUBMITTAL.

Signature _____

Name _____

(Please Print)

Title _____

Company _____

Date _____